NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI008050.01-R1**
DATE:	**05/21/2015**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Steves and Sons**
CODE:	**1846-1**
REVISION DATE:	**07/01/2020**

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Steves and Sons Corporation **203 Humble Avenue** **San Antonio, TX 78225**	**Round Top Opaque Wood** **Outswing Double Door** **w/Surface Bolts** **Configuration:XX** Frame: W-6'3" H-8'0" Panel: W-3'0" H-8'0"

SPECIFICATION	PRODUCT RATING
ASTM E330-02	**Design Pressure: +55/-55 psf** **Qualifying Configurations: X, XX**

Product Tested By: Certified Testing Laboratories
Report No: CTLA-1591W-4
Expiration Date: **May 31, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122