



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

MI Windows & Doors, LLC
P.O. Box 370
Gratz, PA 17030-0370

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION	RECORD OF PRODUCT TESTED		
AAMA/WDMA/CSA 101/I.S.2/A440-11 LC-PG55-2438x1829 (96x72)-FW			
COMPANY AND CODE	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED
MI Windows & Doors, LLC Code: MTL	8820 & 8823	3500 HP PW (FIN & FINLESS) (PVC)(O)(IG)(INS TEMP GL) (ASTM)	<u>FRAME</u> 2438 mm x 1829 mm (96" x 72")

This Certification will expire **April 30, 2031 (extended from April 30, 2026)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Product Tested and Reported by: **Architectural Testing, Inc.**


Report No.: **B9099.01-109-47 & B9101.01-109-47**

**NOTE: ALL CERTIFIED WINDOWS MUST BE GLAZED WITH
TEMPERED GLASS.**

Date of Reports: **May 29, 2012; May 30, 2012**

Date Tests Completed: **April 30, 2012**

Evaluated for Certification: **April 17, 2026**


Associated Laboratories, Inc.

Authorized for Certification: **April 17, 2026**


Fenestration and Glazing Industry Alliance
1900 East Golf Road Schaumburg, IL 60173



(Validator / Operations Administrator)

ACP-04 (Rev. 5/24)