



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

MI Windows & Doors, LLC
P.O. Box 370
Gratz, PA 17030-0370

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION	RECORD OF PRODUCT TESTED		
AAMA/WDMA/CSA 101/I.S.2/A440-11 LC-PG70-1829x1524 (72x60)-FW Negative Design Pressure = -75 psf			
COMPANY AND CODE	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED
MI Windows & Doors, LLC Code: MTL	8822	3500 HP PW (FINLESS) (PVC)(O)(IG)(INS GL) (ASTM)	<u>FRAME</u> 1829 mm x 1524 mm (72" x 60")
Design Pressure (psf): +70/-75 (Pa): +3360/-3600		Water Test Pressure (psf): 12.11 (Pa): 580	

This Certification will expire **April 30, 2031 (extended from April 30, 2026)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.


Product Tested and Reported by: **Architectural Testing, Inc.**

Report No.: **B9101.01-109-47**


Date of Report: **May 30, 2012**

Date Test Completed: **April 30, 2012**

Evaluated for Certification: **April 20, 2026**


Associated Laboratories, Inc.

Authorized for Certification: **April 20, 2026**


Fenestration and Glazing Industry Alliance
1900 East Golf Road Schaumburg, IL 60173



(Validator / Operations Administrator)