

Hallmark® Certificate of Conformance and License (CCL)




AMS, INC.
Administrative Management
Systems, Inc.


Marvin
PO Box 100
401 State Ave N.
Warroad, MN 56763

Mfr ID: 407
For more Information visit www.amscert.com
Website: www.marvin.com
TEL: 218-386-1430

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
407-H-1141.00	Ultimate Casement Picture IZ4 72x71-1/8 or 71-1/8 x 72	101/I.S.2/A440-11	Class CW-PG70; Size Tested 1829mm (72") x 1807mm (71") Type-FW; DP +70/-75 psf; Water Test Press 510Pa (10.65psf); Can. Air Infil/Exfil. Level=Fixed	1829mm	1807mm	E2875.01-201-44	5/19/2015	6/22/2015	5/1/2027
407-H-1141.01	Ultimate Casement Picture IZ4 72x71-1/8 or 71-1/8 x 72	101/I.S.2/A440-08	Class CW-PG70; Size Tested 1829mm (72") x 1807mm (71") Type-FW; DP +70/-75 psf; Water Test Press 510Pa (10.65psf); Can. Air Infil/Exfil. Level=Fixed	1829mm	1807mm	E2875.01-201-44	5/19/2015	6/22/2015	5/1/2027
407-H-1141.02	Ultimate Casement IZ4 3672 mulled to an Ultimate Casement Picture IZ4 7272	ASTM E-1996 12/ASTM E-1886-05	DP +70/-75 psf, Missile D, Wind Zone 4	4572mm	1807mm	E2616.02-201-18	5/19/2015	6/22/2015	5/1/2027
407-H-1141.03	Ultimate Casement IZ4 3672 mulled to an Ultimate Casement Picture IZ4 7272	TAS 201/202/203-94	DP and cycle pressure +70/-75 psf	4572mm	1807mm	E2616.01-201-18	5/19/2015	7/8/2015	5/1/2027
407-H-1141.04	Ultimate Casement IZ4 3672 mulled to an Ultimate Casement Picture IZ4 7272	AAMA 450-10	Class LC-PG70; Size Tested 1829mm (72") Trib Wd-MA Combination Mull-Vertical x 1807mm (71 1/8") Span Type-FW; DP +70/-75 psf, Wind Zone 4; Water Test Press 510Pa (10.65psf); Can. Air Infil/Exfil. Level=Fixed	1829mm Trib width	1807mm Span	E2875.02-201-44	5/19/2015	6/22/2015	5/1/2027

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  **John McFee, VP of Certification Programs, WDMA Hallmark**

By:  **Lucas L. Wenzel, Authorized Representative, AMS**

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com