



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program



AUTHORIZATION FOR PRODUCT CERTIFICATION

MI Windows & Doors, LLC
P.O. Box 370
Gratz, PA 17030-0370

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION	RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-11 R-PG40-1816x2019 (72x80)-SD Negative Design Pressure = -50 psf				
COMPANY AND CODE	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
MI Windows & Doors, LLC Code: MTL	4999	910 SGD (FINLESS) (PVC)(OX)(OG)(INS GL) (REINF)(ASTM)	<u>FRAME</u> 1816 mm x 2019 mm (72" x 80")	<u>SASH</u> 927 mm x 1962 mm (37" x 77")
Design Pressure (psf): +50/-50 (Pa): +2400/-2400		Water Test Pressure (psf): 6.06 (Pa): 290		

This Certification will expire **August 12, 2029 (extended from August 12, 2024 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.


Product Tested and Reported by: **Architectural Testing, Inc.**

Report No.: **A0970.01-109-47**

Date of Report: **August 25, 2010**

Date Test Completed: **August 12, 2010**

Evaluated for Certification: **May 2, 2024**


Associated Laboratories, Inc.

Authorized for Certification: **May 2, 2024**


Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)