

NOTICE OF PRODUCT CERTIFICATION



Company: Steves & Sons Corporation
203 Humble Avenue
San Antonio, TX 78225

Certification No.: NI011563.18-R2
Certification Date: 08/19/2015
Expiration Date: 12/31/2027
Revision Date: 12/08/2021

Product: Opaque Fiberglass Impact Rated Inswing or Outswing Door w/ and w/o Sidelites
(w/Wood Frame unless noted)

Specification: ASTM E330-02/E1886-02/E1996-02

Glazing: Insulating Glass (Laminate-1/8" Annealed glass/0.090" PVB Saflex by Solutia/1/8" Annealed Glass/1/8 Tempered Glass

The "Notice of Product Certification" is only valid if the NAMI Certification Label has been applied to the product as described within this document. The certification label represents product conformity to the applicable specification and that all certification criteria has been satisfied. This product has been approved for listing within NAMI's Certified Product Listing at www.Namicertification.com. NAMI's Certification Program is accredited by The American National Standards Institute (ANSI).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Structural Design Pressure (psf)	Missile Impact Rated	Test Report Number Drawing Number & Comments
X Single	I/S	Opaque	3'2" x 6'10"	+55/-60	Yes	TEL 01520034/TEL 01520035/TEL 01520037 Max Panel Size: 3'0" x 6'8" Drawings: FL-17901.1
X Single	O/S	Opaque	3'2" x 6'10"	+55/-55	Yes	TEL 01520034/TEL 01520035/TEL 01520037 Max Panel Size: 3'0" x 6'8" Drawings: FL-17901.1
XX Double	I/S	Opaque	6'2" x 6'10"	+50/-55	Yes	TEL 01520034/TEL 01520035/TEL 01520037 Max Panel Size: 3'0" x 6'8" Drawings: FL-17901.4
XX Double	O/S	Opaque	6'2" x 6'10"	+50/-50	Yes	TEL 01520034/TEL 01520035/TEL 01520037 Max Panel Size: 3'0" x 6'8" Drawings: FL-17901.4
XO/OX Single w/Sidelite	I/S	Opaque Door Glazed Sidelite	6'4" x 6'10"	+55/-60	Door-Yes Sidelite-Yes	TEL 01520034/TEL 01520035/TEL 01520037 Max Panel Size: 3'0" x 6'8" Drawings: FL-17901.2/Boxed Sidelite-Reinforced Mullion
XO/OX Single w/Sidelite	O/S	Opaque Door Glazed Sidelite	6'4" x 6'10"	+55/-55	Door-Yes Sidelite-Yes	TEL 01520034/TEL 01520035/TEL 01520037 Max Panel Size: 3'0" x 6'8" Drawings: FL-17901.2/Boxed Sidelite-Reinforced Mullion
OXO Single w/Sidelites	I/S	Opaque Door Glazed Sidelites	9'7" x 6'10"	+55/-60	Door-Yes Sidelites-Yes	TEL 01520034/TEL 01520035/TEL 01520037 Max Panel Size: 3'0" x 6'8" Drawings: FL-17901.3/Boxed Sidelite-Reinforced Mullion
OXO Single w/Sidelites	O/S	Opaque Door Glazed Sidelites	9'7" x 6'10"	+55/-55	Door-Yes Sidelites-Yes	TEL 01520034/TEL 01520035/TEL 01520037 Max Panel Size: 3'0" x 6'8" Drawings: FL-17901.3/Boxed Sidelite-Reinforced Mullion
OXXO Double w/Sidelites	I/S	Opaque Door Glazed Sidelites	12'8" x 6'10"	+50/-55	Door-Yes Sidelites-Yes	TEL 01520034/TEL 01520035/TEL 01520037 Max Panel Size: 3'0" x 6'8" Drawings: FL-17901.5/Boxed Sidelite-Reinforced Mullion
OXXO Double w/Sidelites	O/S	Opaque Door Glazed Sidelites	12'8" x 6'10"	+50/-50	Door-Yes Sidelites-Yes	TEL 01520034/TEL 01520035/TEL 01520037 Max Panel Size: 3'0" x 6'8" Drawings: FL-17901.5/Boxed Sidelite-Reinforced Mullion

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072

Tel: (804) 684-5124/Email: nami@namiinc.com

NAMI AUTHORIZED SIGNATURE: _____