

NOTICE OF PRODUCT CERTIFICATION



Company: Steves & Sons Corporation
203 Humble Avenue
San Antonio, TX 78225

Certification No.: NI011563.21-R1
Certification Date: 08/19/2015
Expiration Date: 12/31/2027
Revision Date: 07/03/2020

Product: Glazed Fiberglass Inswing or Outswing Door w/ and w/o Sidelites
(w/Wood Frame unless noted)

Specification: ASTM E330-02

Glazing: Insulating Glass (1/8" Tempered)

The "Notice of Product Certification" is only valid if the NAMI Certification Label has been applied to the product as described within this document. The certification label represents product conformity to the applicable specification and that all certification criteria has been satisfied. This product has been approved for listing within NAMI's Certified Product Listing at www.Namicertification.com. NAMI's Certification Program is accredited by The American National Standards Institute (ANSI).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Structural Design Pressure (psf)	Missile Impact Rated	Test Report Number Drawing Number & Comments
X Single	I/S	Glazed	3'2" x 8'2"	+50/-55	No	TEL 01530201/TEL 01530200/W-1730 Max Panel Size: 3'0" x 8'0"/w/Security Strikes & Corner Screw Drawings: FL-17904.1
X Single	O/S	Glazed	3'2" x 8'2"	+50/-50	No	TEL 01530201/TEL 01530200/W-1730 Max Panel Size: 3'0" x 8'0"/w/Security Strikes & Corner Screw Drawings: FL-17904.1
XO/OX Single w/Sidelite	I/S	Glazed Door Glazed Sidelite	4'7" x 8'2"	+50/-55	Door-No Sidelite-No	TEL 01530201/TEL 01530200/W-1730 Max Panel Size: 3'0" x 8'0" Drawings: FL-17904.1/Boxed Sidelite-2X Reinforced Mullion
XO/OX Single w/Sidelite	O/S	Glazed Door Glazed Sidelite	4'7" x 8'2"	+50/-50	Door-No Sidelite-No	TEL 01530201/TEL 01530200/W-1730 Max Panel Size: 3'0" x 8'0" Drawings: FL-17904.1/Boxed Sidelite-2X Reinforced Mullion
OXO Single w/Sidelites	I/S	Glazed Door Glazed Sidelite	5'10" x 8'2"	+50/-55	Door-No Sidelites-No	TEL 01530201/TEL 01530200/W-1730 Max Panel Size: 3'0" x 8'0" Drawings: FL-17904.1/Boxed Sidelite-2X Reinforced Mullion
OXO Single w/Sidelites	O/S	Glazed Door Glazed Sidelite	5'10" x 8'2"	+50/-50	Door-No Sidelites-No	TEL 01530201/TEL 01530200/W-1730 Max Panel Size: 3'0" x 8'0" Drawings: FL-17904.1/Boxed Sidelite-2X Reinforced Mullion

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072
Tel: (804) 684-5124/Fax: (804) 684-5122

NAMI AUTHORIZED SIGNATURE: _____

A handwritten signature in black ink, appearing to be "Shi" or similar, written over a horizontal line.