

Hallmark® Certificate of Conformance and License (CCL)



Marvin
PO Box 100
401 State Ave N.
Warroad, MN 56763

Mfr ID: 407
For more Information visit www.amscert.com
Website: www.marvin.com
TEL: 218-386-1430

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
407-H-1145.00	Ultimate Outswing French Door IZ4 3080 (O)	101/I.S.2/A440-11	Class LC-PG65; Size Tested 956mm x 2426mm (37x95") Type-FD; DP +65/-80 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	956mm	2426mm	E4540.02-201-44	6/22/2015	7/22/2015	5/1/2027
407-H-1145.01	Ultimate Outswing French Door IZ4 3080 (O)	101/I.S.2/A440-08	Class LC-PG65; Size Tested 956mm x 2426mm (37x95") Type-FD; DP +65/-80 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	956mm	2426mm	E4540.02-201-44	6/22/2015	7/22/2015	5/1/2027
407-H-1145.02	Ultimate Outswing French Door IZ4 3080 (O)	ASTM E-1996 12/ASTM E-1886-05	DP +65/-80 psf, Missile D, Wind Zone 4	956mm	2426mm	E6025.02-201-18	6/4/2015	7/24/2015	5/1/2027
407-H-1145.03	Ultimate Outswing French Door IZ4 3080 (O)	TAS 201/202/203-94	DP & Cycle Pressure +65/-80 psf, Large Missile	956mm	2426mm	E6025.01-201-18	6/4/2015	7/24/2015	5/1/2027
407-H-1145.04	Ultimate Outswing French Door IZ4 3080 (O) FD W/ Raised Panel	101/I.S.2/A440-11	Class LC-PG65; Size Tested 952mm (37") x 2426mm (95") Type-FD; DP +65/-80 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=Fixed	952mm	2426mm	E4541.01-201-44	6/12/2015	7/24/2015	5/1/2027
407-H-1145.05	Ultimate Outswing French Door IZ4 3080 (O) FD W/ Raised Panel	101/I.S.2/A440-08	Class LC-PG65; Size Tested 952mm x 2426mm (37x95") Type-FD; DP +65/-80 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=Fixed	952mm	2426mm	E4541.01-201-44	6/12/2015	7/24/2015	5/1/2027
407-H-1145.06	Ultimate Outswing French Door IZ4 3080 (O) SLT W / Raised Panel	101/I.S.2/A440-11	Class CW-PG65; Size Tested 952mm x 2426mm (37x95") Type-SLT; DP +65/-80 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=Fixed	952mm	2426mm	E4541.01-201-44	6/12/2015	7/24/2015	5/1/2027
407-H-1145.07	Ultimate Outswing French Door IZ4 3080 (O) SLT W / Raised Panel	101/I.S.2/A440-08	Class CW-PG65; Size Tested 952mm x 2426mm (37x95") Type-SLT; DP +65/-80 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=Fixed	952mm	2426mm	E4541.01-201-44	6/12/2025	7/24/2015	5/1/2027

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Marvin
PO Box 100
401 State Ave N.
Warroad, MN 56763

Mfr ID: 407
For more Information visit www.amscert.com
Website: www.marvin.com
TEL: 218-386-1430

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
407-H-1145.08	Ultimate Outswing French Door IZ4 3080 (O) W / Raised Panel	ASTM E-1996 12/ASTM E-1886-05	DP +65/-80 psf, Missile D, Wind Zone 4	952mm	2426mm	E4538.02-201-18	6/12/2015	7/24/2015	5/1/2027
407-H-1145.09	Ultimate Outswing French Door IZ4 3080 (O) W / Raised Panel	TAS 201/202/203-94	DP & Cycle Pressure +65/-80 psf, Large Missile	952mm	2426mm	E4538.01-201-18	6/9/2015	7/24/2015	5/1/2027

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By: John McFee John McFee, VP of Certification Programs, WDMA Hallmark

By: Lucas L. Wenzel Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com