

AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

MI Windows & Doors, LLC
P.O. Box 370
Gratz, PA 17030-0370

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION	RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S. 2/A440-11 LC-PG35-1524x914 (60x36)-AP				
COMPANY AND CODE	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
MI Windows & Doors, LLC Code: MTL	13553 & 13552	9660 AWNING (FIN & FINLESS) (PVC)(X)(OG)(INS GL) (ASTM)	<u>FRAME</u> 1524 mm x 914 mm (60" x 36")	<u>VENT</u> 1483 mm x 873 mm (58" x 34")
Design Pressure (psf): +40/-35 (Pa): +1920/-1680			Water Test Pressure (psf): 12.11 (Pa): 580	

This Certification will expire **December 10, 2029 (extended from December 10, 2024 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.


Product Tested and Reported by: **Architectural Testing, Inc.**

Report No.: **E3405.01-109-47 & E3406.01-109-47**

Date of Reports: **January 12, 2015**

Date Test Completed: **December 10, 2014**

Evaluated for Certification: **November 25, 2024**


Associated Laboratories, Inc.

Authorized for Certification: **November 25, 2024**



(Validator / Operations Administrator)

ACP-04 (Rev. 5/24)

Fenestration and Glazing Industry Alliance
1900 East Golf Road Schaumburg, IL 60173