AAMA CERTIFICATION PROGRAM

An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

Elixir Door and Metals Co.
1215 Pope Dr.
Douglas, GA 31533

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION	RECORD OF PRODUCT TESTED			
AAMA ALTERNATE DOOR CERTIFICATION PROGRAM ASTM E330-14 DP = ±50 psf STP = ±75 psf				
COMPANY & CODE	**CPD NO.**	**SERIES MODEL & PRODUCT DESCRIPTION**	**MAXIMUM SIZE TESTED**	
Elixir Door and Metals Co. Code: EXR	**19344**	**430-W9 VINYL LAMINATED OUTSWING DOOR (AL)(ST)(X) (FIXED INSERT W/TEMP GL)**	**FRAME 38" x 82"**	**LEAF 36" x 80" x 1-1/2" FIXED INSERT 20" x 36"**

This Certification will expire **August 25, 2030 (extended from August 25, 2025 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Product Tested and Reported by: **Construction Consulting Laboratory**

Report No.: **CCL-20-168**

Date of Report: **September 28, 2020**
Date Test Completed: **August 25, 2020**

Evaluated for Certification: **June 20, 2024**

Associated Laboratories, Inc.

A·L·I

(Validator / Operations Administrator)

Authorized for Certification: **June 20, 2024**

Fenestration and Glazing Industry Alliance
1900 East Golf Road Schaumburg, IL 60173