

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015113.01
DATE: 12/09/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Continental Glass
CODE: 2103-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Continental Glass Systems, LLC 325 West 74 Place Hialeah, FL 33014	Series "2900" Aluminum Sliding Glass Door Configuration: OX Glazing: IG-1/4" Tempered Glass/1/4" Heat Strengthened Glass/0.09" Sentryglas by Kuraray Interlayer/1/4" Heat Strengthened Glass Frame: W-2599mm(102.31") H-3785mm(149") DLO: W-1111mm(43.75") H-3567mm(140.44")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: 2880 Pa (60 psf) Positive Design Pressure: 2880 Pa (60 psf) Negative Design Pressure: 3305 Pa (69 psf) Water Penetration Resistance Test Pressure: 430 Pa (9.00 psf) Large Missile Impact Rated

Product Tested By: Blackwater Testing, Inc.

Report No: BT-CON-19-022

Expiration Date: October 31, 2024

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD", is written over the signature line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122