

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413


For more Information visit www.amscert.com


Website: www.kolbewindows.com

TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
413-H-1129.07	Ultra XL Sterling Double Hung HP (R&D #14104)	101/I.S.2/A440-11	Class LC-PG60; Size Tested 1219mm x 3048mm Type-H; DP +65/-65 psf; Water Test Press 440Pa (9.19psf); Can. Air Infil/Exfil. Level=A3	1219mm	3048mm	ESP018721P-1665	2/13/2015	1/12/2025
413-H-1129.20	Ultra XL Sterling Double Hung IPD4, single glaze & insulated (R&D #20049, 20050)	ASTM E-1996 17/ASTM E-1886 13a	DP +60/-60 psf, Missile D, Wind Zone 4	1219mm	3048mm	QCT21-6279.01	7/13/2021	5/18/2031
413-H-1129.21	Ultra XL Sterling Double Hung IPD4, single glaze & insulated (R&D #20049, 20050)	ASTM E-330-14	DP +60/-60 psf	1219mm	3048mm	QCT21-6279.01	7/13/2021	5/18/2031

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  **John McFee, VP of Certification Programs, WDMA Hallmark**

By:  **Lucas L. Wenzel, Authorized Representative, AMS**

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com