

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012723-R4
DATE: 07/15/2015
CERTIFICATION PROGRAM: Structural
COMPANY: Atrium
CODE: 1373-1
REVISION DATE: 03/27/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namincertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Companies, Inc. 9001 Ambassador Row Dallas, TX 75247	Series "700" Vinyl Shaped Picture Window w/ & w/o Fin Installation Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1829mm(72") H-1829mm(72") DLO: W-1702mm(67") H-1702mm(67")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class CW-PG55 1829 x 1829 (72 x 72)-FW FW-CW55 1829 x 1829 (72 x 72) Design Pressure: ±2640 Pa (55 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf)

Product Tested By: Architectural Testing, Inc.
Report No: A5412.01-801-47/W-1996
Expiration Date: July 31, 2029

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@naminc.com

NOPC-03/30/2023