

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI012503-R4  
**DATE:** 02/05/2015  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Nan Ya Plastics  
**CODE:** 661-1  
**REVISION DATE:** 06/18/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                          | PRODUCT DESCRIPTION                                                                                                                                                                                                                                                                                                      |
|---------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Nan Ya Plastics Corporation U.S.A.</b><br><b>4016 Shadrack St.</b><br><b>Houston, TX 77013</b> | <b>Series "SLPS"</b><br><b>In-Swing Glazed Fiberglass</b><br><b>Side-Hinged Patio Door (Non-Impact)</b><br><br>Configuration: OXX/O<br>Glazing: Insulating Glass (Tempered)<br><br>Frame: W-3594mm(141.50") H-2089mm(82.25")<br><br>Panel: W-876mm(34.50") H-2008mm(79.06")<br><br>DLO: W-635mm(25.00") H-1600mm(63.00") |

| SPECIFICATION                                                  | PRODUCT RATING                                                                                                                                                                                                                                                                                                                                               |
|----------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b><br><b>CSA A440S1-09</b> | <b>Class R-PG40 3594 x 2089 (142 x 82)-SHD</b><br><b>Positive Design Pressure: 2880 Pa (60 psf)</b><br><b>Negative Design Pressure: 2880 Pa (60 psf)</b><br>Water Penetration Resistance Test Pressure: 288 Pa(6.0 psf)<br><b>Canadian Air Infiltration/Exfiltration Level: A3</b><br>Qualified Configurations:<br>O/X/OX/XO/OXO/XX/OXX/XXO/OXX/O/O/XXO/OXXO |

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-3990-01  
Expiration Date: November 30, 2036

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

**4794 George Washington Memorial Highway**

**Hayes, VA 23072**

**Tel: (804) 684-5124**

**Email: [nami@namiinc.com](mailto:nami@namiinc.com)**

NOPC-03/30/2023