

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011188.04-R4
DATE: 02/11/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Moss Supply
CODE: 206-1
REVISION DATE: 10/26/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Moss Supply Company 5001 North Graham Street Charlotte, NC 28269	Series "3300/3400" New Construction Vinyl Single Hung Window Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1016mm(40") H-1880mm(74") Sash: W-964mm(37.94") H-922mm(36.31")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG50 1016 x 1880 (40 x 74)-H Design Pressure: ± 2400 Pa (± 50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Quast Consulting & Testing, Inc.
Report No: QCT12-2814.01
Expiration Date: January 31, 2031

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi" or similar, written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122