

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012705.02-R5
DATE: 07/03/2015
CERTIFICATION PROGRAM: Structural
COMPANY: Atrium
CODE: 2187-1
REVISION DATE: 02/17/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Corporation 300 Welcome Center Blvd. Welcome, NC 27374	Series "5700/105/8050/3050/5/900/1050" Vinyl Horizontal Sliding Window w/Fin & Finless Installation Configuration: XOX Glazing: Insulating Glass (Annealed) Frame: W-2438mm(96") H-1524mm(60") Vent: W-813mm(32") H-1476mm(56.13") DLO: W-724mm(28.5") H-1455mm(57.31")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class R-PG20 2438 x 1524 (96 x 60)-HS HS-R20 2438 x 1524 (96 x 60) Design Pressure: ±960 Pa (20 psf) Water Penetration Resistance Test Pressure: 180 Pa (3.76 psf)

Product Tested By: Architectural Testing, Inc.
Report No: D9501.01-801-47/A9926.01-801-47/W-2009
Expiration Date: July 31, 2030

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023