

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012979-R4
DATE: 01/06/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Atrium
CODE: 1373-1
REVISION DATE: 08/05/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Corporation 300 Welcome Center Blvd. Welcome, NC 27374	Series "8700/6000/1600/80/3500" Vinyl Horizontal Sliding Window w/Finless Installation Configuration: XX Glazing: Insulating Glass (Annealed) Frame: W-1829mm(72") H-1219mm(48") Sash: W-905mm(35.63") H-1130mm(44.5") DLO: W-832mm(32.75") H-1060mm(41.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class R-PG30 1829 x 1219 (72 x 48)-HS HS-R30 1829 x 1219 (72 x 48) Design Pressure: ±1440 Pa (30 psf) Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf)

Product Tested By: Architectural Testing, Inc.
Report No: B6836.01-801-47-R1/W-2009
Expiration Date: January 31, 2030

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023