

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016462
DATE: 01/09/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Silverline
CODE: 3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products 5020 Weston Parkway Cary, NC 27513	Series "2900/4900/70" 2902/4902 Vinyl Twin Single Hung Window Configuration: O/XO/X Glazing: Insulating Glass (Annealed) Frame: W-2426mm(95.50") H-1880mm(74") Sash: W-1153mm(45.38") H-927mm(36.50") DLO: W-1092mm(43") H-864mm(34")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG30 2426 x 1880 (96 x 74)-H Design Pressure: ± 1440 Pa (± 30 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)

Product Tested By: Architectural Testing, Inc.
Report No: C0375.01-109-47
Expiration Date: **December 31, 2028**

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com