

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI016463.05  
**DATE:** 02/05/2025  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Silverline  
**CODE:** 3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                   | PRODUCT DESCRIPTION                                                                                                                                                                                                                                                                                                              |
|--------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Silverline Building Products</b><br><b>5020 Weston Parkway</b><br><b>Cary, NC 27513</b> | <b>Series "2900/4900"</b><br><b>2903/4903/2920/4920</b><br><b>Vinyl Triple Single Hung Window</b><br><b>(Fin)</b><br><br>Configuration: O/XO/XO/X<br>Glazing: Insulating Glass (Annealed)<br><br>Frame: W-2737mm(107.75") H-1575mm(62")<br><br>Sash: W-854mm(33.63") H-775mm(30.50")<br><br>DLO: W-791mm(31.13") H-714mm(28.13") |

| SPECIFICATION                          | PRODUCT RATING                                                                                                                                                       |
|----------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> | <b>Class R-PG30 2737 x 1575* (108 x 62*)-H</b><br><b>Design Pressure: ±1440 Pa (±30 psf)</b><br><b>Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf)</b> |

Product Tested By: Intertek, PLC  
Report No: E9222.01-109-47/D9359.01-109-47  
Expiration Date: January 31, 2029

Administrator's Signature: 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023