NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013176-R3**
DATE:	**05/09/2016**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Loewen**
CODE:	**1862-1**
REVISION DATE:	**10/01/2025**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Loewen **77 Highway 52 West** **Steinbach, Manitoba R5G 1B2**	**Series "28CA Traditional"** **Aluminum Clad Wood Casement Window** Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1067mm(42") H-2438mm(96") Vent: W-1022mm(40.25") H-2389mm(94") DLO: W-912mm(35.88") H-2280mm(89.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 **AAMA/WDMA/CSA 101/I.S.2/A440-08** **CSA A440S1-09**	**Class CW-PG50 1067 x 2438 (42 x 96)-C** **Design Pressure: 2400 Pa (50 psf)** **Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf)** **Canadian Air Infiltration/Exfiltration Level: A3**

Product Tested By: Architectural Testing, Inc.
Report No: F2622.01-750-44/W-1921
Expiration Date: **December 31, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com