

Hallmark® Certificate of Conformance and License (CCL)



Sierra Pacific Windows
11605 Reading Road
PO Box 8489
PO Box 8489
Red Bluff, CA 96080

Mfr ID: 436

For more Information visit www.amscert.com

Website:

TEL: 530-527-9620

Product No.	Product Name	Standard	Rating	Wide	High	Test Method
436-H-523.30	Clad Energy Saver Direct Set 98"x84" Individual Unit	101/I.S.2/A440-08	Class CW-PG50; Size Tested 2483mm (98") x 2130mm (84") Type-FW; DP +50/-55 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=Fixed	2483mm (98")	2130mm (84")	TCT008

WDMA HEREBY CERTIFIES that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected by WDMA, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By: John McFee John McFee, VP of Certification

By: Rhonda Schotz Rhonda Schotz, Author

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Manager
PO Box 730, 10
Sackets Harbor
TEL (315)646-2