

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013004.02  
**DATE:** 05/19/2016  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Continental Glass  
**CODE:** 2103-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Continental Glass Systems, LLC</b> <b>325 West 74 Place</b> <b>Hialeah, FL 33014</b>	<b>Series "2800"</b> <b>Aluminum Lift &amp; Sliding</b> <b>Glass Door</b> <b>w/Reinforcement</b>  Configuration: OXXXXO Glazing: Monolithic-1/4" Heat Strengthened Glass/0.090" Kuraray Sentry Glass Interlayer/1/4" Heat Strengthened Glass  Frame: W-9112mm(358.75") H-3353mm(132") DLO: W-1386mm(54.56") H-3053mm(120.19")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: 7182 Pa (150 psf)</b> <b>Large Missile Impact Rated</b>

Product Tested By: Blackwater Testing, Inc  
Report No: BT-CON-15-018B  
Expiration Date: December 31, 2019

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

**Fax: (804) 684-5122**

