

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013033.01
DATE: 03/07/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Continental Glass
CODE: 2103-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Continental Glass Systems, LLC 325 West 74 Place Hialeah, FL 33014	Series "200" Aluminum Curtain Wall System Configuration: OOOOO/OOO Glazing: Laminate-1/4" Heat Strengthened Glass/0.060" PVB Interlayer/1/4" Heat Strengthened Glass Frame: W-6172mm(243") H-5582mm(219.75") DLO: W-1143mm(45") H-3099mm(122")

SPECIFICATION	PRODUCT RATING
ASTM E283-04/E330-02/E331-00 AAMA 501-05 TAS 201/202/203-94	Design Pressure: 4549 Pa (95 psf) Small Missile Impact Rated

Product Tested By: Blackwater Testing, Inc
Report No: BT-CON-15-015
Expiration Date: January 31, 2019

A handwritten signature in black ink, appearing to be 'Shi' or similar, written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122