

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012963.02-R5
DATE: 12/14/2015
CERTIFICATION PROGRAM: Structural
COMPANY: Comfort View
CODE: 2111-1
REVISION DATE: 05/30/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Comfort View Products, LLC 320 Coweta Industrial Park Building 7, Suite C-1 Newnan, GA 30265	Series "900" Vinyl Single Hung Window w/Reinforced Sash Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1118mm(44") H-1829mm(72") Sash: W-1046mm(41.19") H-886mm(34.88") DLO: W-997mm(39.25") H-827mm(32.56")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG50 1118 x 1829 (44 x 72)-H Design Pressure: ± 2400 Pa (50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2640 Pa (55 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Architectural Testing, Inc.
Report No: E5439.02-501-47/W-1892
Expiration Date: September 30, 2026

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com