NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI012996.03-R4**
DATE:	**01/25/2016**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Comfort View**
CODE:	**2111-1**
REVISION DATE:	**05/03/2023**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Comfort View Products, LLC **320 Coweta Industrial Park** **Building 7, Suite C-1** **Newnan, GA 30265**	**Series "900"** **Vinyl Single Hung Window** **w/Reinforced Sash** Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-914mm(36") H-1829mm(72") Sash: W-841mm(33.13") H-884mm(34.81") DLO: W-794mm(31.25") H-827mm(32.56")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 **AAMA/WDMA/CSA 101/I.S.2/A440-08** **AAMA/WDMA/CSA 101/I.S.2/A440-05**	**Class R-PG50 914 x 1829* (36 x 72*)-H** **H-R45 914 x 1829* (36 x 72*)** **Design Pressure: 2400 Pa (50 psf)** **Positive Design Pressure: 2880 Pa (60 psf)** **Negative Design Pressure: 3120 Pa (65 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)**

Product Tested By: Architectural Testing, Inc.
Report No: E8064.02-501-47/W-1892
Expiration Date: **May 31, 2026**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com