

Hallmark® Certificate of Conformance and License (CCL)



Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413

For more Information visit www.amscert.com

Website: www.kolbewindows.com

TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
413-H-1289.61	VistaLuxe 1221 Outswing Door, 2wide Combination Mull Active/Stat (R&D New 24010)	101/I.S.2/A440-22	Class LC-PG50; Size Tested 971mm x 2499mm Type-SHD; DP +50/-50 psf; Water Test Press 360Pa (7.52psf)	971mm	2499mm	QCT24-7203.25	10/9/2024	10/17/2024	8/12/2034
413-H-1289.62	VistaLuxe 1221 Outswing Door, 2wide Combination Mull Active/Stat (R&D New 24010)	101/I.S.2/A440-17	Class LC-PG50; Size Tested 971mm x 2499mm Type-SHD; DP +50/-50 psf; Water Test Press 360Pa (7.52psf)	971mm	2499mm	QCT24-7203.25	10/9/2024	10/17/2024	8/12/2034
413-H-1289.63	VistaLuxe 1221 Outswing Door, 2wide Combination Mull Active/Stat (R&D New 24010)	CSA A440 S1-19	Class LC-PG50; Size Tested 971mm x 2499mm Type-SHD; DP +2400/-2400 Pa; Water Test Press 360Pa; Can. Air Infil/Exfil. Level=A3	971mm	2499mm	QCT24-7203.25	10/9/2024	10/17/2024	8/12/2034
413-H-1289.64	VistaLuxe 1221 Outswing Door, 2wide Combination Mull Active/Stat (R&D New 24010)	CSA A440 S1-17	Class LC-PG50; Size Tested 971mm x 2499mm Type-SHD; DP +2400/-2400 Pa; Water Test Press 360Pa; Can. Air Infil/Exfil. Level=A3	971mm	2499mm	QCT24-7203.25	10/9/2024	10/17/2024	8/12/2034
413-H-1289.65	VistaLuxe 1221 Outswing Door, 2wide Combination Mull Active/Stat (R&D New 24010)	101/I.S.2/A440-22	Class LC-PG50; Size Tested 968mm x 2499mm Type-FD; DP +50/-50 psf; Water Test Press 360Pa (7.52psf)	968mm	2499mm	QCT24-7203.25	10/9/2024	10/17/2024	8/12/2034
413-H-1289.66	VistaLuxe 1221 Outswing Door, 2wide Combination Mull Active/Stat (R&D New 24010)	101/I.S.2/A440-17	Class LC-PG50; Size Tested 968mm x 2499mm Type-FD; DP +50/-50 psf; Water Test Press 360Pa (7.52psf)	968mm	2499mm	QCT24-7203.25	10/9/2024	10/17/2024	8/12/2034
413-H-1289.67	VistaLuxe 1221 Outswing Door, 2wide Combination Mull Active/Stat (R&D New 24010)	CSA A440 S1-19	Class LC-PG50; Size Tested 968mm x 2499mm Type-FD; DP +2400/-2400 Pa; Water Test Press 360Pa; Can. Air Infil/Exfil. Level=Fixed	968mm	2499mm	QCT24-7203.25	10/9/2024	10/17/2024	8/12/2034
413-H-1289.68	VistaLuxe 1221 Outswing Door, 2wide Combination Mull Active/Stat (R&D New 24010)	CSA A440 S1-17	Class LC-PG50; Size Tested 968mm x 2499mm Type-FD; DP +2400/-2400 Pa; Water Test Press 360Pa; Can. Air Infil/Exfil. Level=Fixed	968mm	2499mm	QCT24-7203.25	10/9/2024	10/17/2024	8/12/2034
413-H-1289.69	VistaLuxe 1221 Outswing Door, 2wide Combination Mull Active/Stat (R&D New 24010)	101/I.S.2/A440-22	Class LC-PG50; Size Tested 971 mm Tributary width x 2499mm span Type-MA; DP +50/-50 psf; Water Test Press 360Pa (7.52psf)	971 mm Tributary width	2499mm span	QCT24-7203.25	10/9/2024	10/17/2024	8/12/2034

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413


For more Information visit www.amscert.com

Website: www.kolbewindows.com

TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
413-H-1289.70	VistaLuxe 1221 Outswing Door, 2wide Combination Mull Active/Stat (R&D New 24010)	101/I.S.2/A440-17	Class LC-PG50; Size Tested 971 mm Tributary width x 2499mm span Type-MA; DP +50/-50 psf; Water Test Press 360Pa (7.52psf)	971 mm Tributary width	2499mm span	QCT24-7203.25	10/9/2024	10/17/2024	8/12/2034
413-H-1289.71	VistaLuxe 1221 Outswing Door, 2wide Combination Mull Active/Stat (R&D New 24010)	CSA A440 S1-19	Class LC-PG50; Size Tested 971 mm Tributary width x 2499mm span Type-MA; DP +2400/-2400 Pa; Water Test Press 360Pa; Can. Air Infil/Exfil. Level=A3	971 mm Tributary width	2499mm span	QCT24-7203.25	10/9/2024	10/17/2024	8/12/2034
413-H-1289.72	VistaLuxe 1221 Outswing Door, 2wide Combination Mull Active/Stat (R&D New 24010)	CSA A440 S1-17	Class LC-PG50; Size Tested 971 mm Tributary width x 2499mm span Type-MA; DP +2400/-2400 Pa; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	971 mm Tributary width	2499mm span	QCT24-7203.25	10/9/2024	10/17/2024	8/12/2034

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  **John McFee, VP of Certification Programs, WDMA Hallmark**

By:  **Lucas L. Wenzel, Authorized Representative, AMS**

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com