

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013034.01-R2
DATE: 03/07/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Exclusive
CODE: 566-1
REVISION DATE: 07/08/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Exclusive Wood Doors 2000 Northwest 95th Avenue Doral, FL 33172	Series " Exterior Swinging Doors - Outswing Opaque Wood Door-L.M.I" Configuration: XX Frame: W-1886mm(74.25") H-3099mm(122") Panel: W-914mm(36") H-3048mm(120")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±3352 Pa (70 psf) Large Missile Impact Rated

Product Tested By: Certified Testing Laboratories
Report No: CTLA 2016W
Expiration Date: **March 31, 2022**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122