

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413

For more Information visit www.amscert.com

Website: www.kolbewindows.com

TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
413-H-1289.42	VistaLuxe Outswing Door, 2-1/8" Panel, 3" Stiles, mulled to VistaLuxe Direct Set, w/VistaLuxe Outswing Transom mulled to VistaLuxe Awning stacked above, steel reinforced vertical & horizontal mulls, SP (R&D #13139)	101/I.S.2/A440-11	Class LC-PG50; Size Tested 1524mm x 610mm * Type-AP; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	1524mm	610mm	ESP017952P-1622	8/8/2018	10/20/2024
413-H-1289.43	VistaLuxe Outswing Door, 2-1/8" Panel, 3" Stiles, mulled to VistaLuxe Direct Set, w/VistaLuxe Outswing Transom mulled to VistaLuxe Awning stacked above, steel reinforced vertical & horizontal mulls, SP (R&D #13139)	101/I.S.2/A440-11	Class LC-PG50; Size Tested 1524mm x 2494mm Type-FW; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	1524mm	2494mm	ESP017952P-1622	8/8/2018	10/20/2024
413-H-1289.44	VistaLuxe Outswing Door, 2-1/8" Panel, 3" Stiles, mulled to VistaLuxe Direct Set, w/VistaLuxe Outswing Transom mulled to VistaLuxe Awning stacked above, steel reinforced vertical & horizontal mulls, SP (R&D #13139)	101/I.S.2/A440-11	Class LC-PG50; Size Tested 3110mm span/1248mm trib width (122.44 in/49.13 in) Type -MA; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3 (Reinforced Combination Vertical Mull)	1248mm trib width	3110mm span	ESP017952P-1622	8/8/2018	10/20/2024
413-H-1289.45	VistaLuxe Outswing Door, 2-1/8" Panel, 3" Stiles, mulled to VistaLuxe Direct Set, w/VistaLuxe Outswing Transom mulled to VistaLuxe Awning stacked above, steel reinforced vertical & horizontal mulls, SP (R&D #13139)	101/I.S.2/A440-11	Class LC-PG50; Size Tested 1524mm span/1555mm trib width (60 in/61.22 in) Type-MA; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3 (Reinforced Combination Horizontal Mull)	1555mm trib width	1524mm span	ESP017952P-1622	8/8/2018	10/20/2024
413-H-1289.46	VistaLuxe Outswing Door, 2-1/8" Panel, 3" Stiles, mulled to VistaLuxe Direct Set, w/VistaLuxe Outswing Transom mulled to VistaLuxe Awning stacked above, steel reinforced vertical & horizontal mulls, SP (R&D #13139)	101/I.S.2/A440-08	Class LC-PG50; Size Tested 2496mm x 3110mm Type-SHD; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	2496mm	3110mm	ESP017952P-1622	8/15/2018	10/20/2024
413-H-1289.47	VistaLuxe Outswing Door, 2-1/8" Panel, 3" Stiles, mulled to VistaLuxe Direct Set, w/VistaLuxe Outswing Transom mulled to VistaLuxe Awning stacked above, steel reinforced vertical & horizontal mulls, SP (R&D #13139)	AAMA 450-10	Class LC-PG50; Size Tested 3110mm span/1248mm trib width (122.44 in/49.13 in) Type -MA; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3 (Reinforced Combination Vertical Mull)	1248mm trib width	3110mm span	ESP017952P-1622	8/8/2018	10/20/2024

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413


For more Information visit www.amscert.com


Website: www.kolbewindows.com

TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
413-H-1289.48	VistaLuxe Outswing Door, 2-1/8" Panel, 3" Stiles, mulled to VistaLuxe Direct Set, w/VistaLuxe Outswing Transom mulled to VistaLuxe Awning stacked above, steel reinforced vertical & horizontal mulls, SP (R&D #13139)	AAMA 450-10	Class LC-PG50; Size Tested 1524mm span/1555mm trib width (60 in/61.22 in) Type-MA; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3 (Reinforced Combination Horizontal Mull)	2496mm	3110mm	ESP017952P-1622	8/8/2018	10/20/2024

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  *John McFee, VP of Certification Programs, WDMA Hallmark*

By:  *Rhonda Schotz, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com