NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013111.28-R6**
DATE:	**04/12/2016**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Atrium**
CODE:	**2187-1**
REVISION DATE:	**11/20/2025**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Companies, Inc. **300 Welcome Center Blvd.** **Welcome, NC 27374**	**Series "130" Mulled** **Vinyl Single Hung Window** **w/Transom & Finless Installation** Configuration: O/O/X Glazing: Insulating Glass (Annealed) Frame: W-1219mm(48") H-2756mm(108.5") Sash: W-1169mm(45.94") H-889mm(35") DLO: W-1099mm(43.25") H-795mm(31.31")

SPECIFICATION	PRODUCT RATING
AAMA 450-10 **AAMA/WDMA/CSA 101/I.S.2/A440-17** **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08** **AAMA/WDMA/CSA 101/I.S.2/A440-05**	**Applied Rating: R50** **Mulled Fenestration Rating: R50** **Class R-PG50 1219 x 2756 (48 x 109)-H** **Design Pressure: ±2400 Pa (50 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)**

Product Tested By: Architectural Testing, Inc.
Report No: D5171.01-801-47/D2322.01-801-47/D5167.01-801-47(Gateway)/W-2009
Expiration Date: **April 30, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com