NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013209-R4**
DATE:	**05/18/2016**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Atrium**
CODE:	**2187-1**
REVISION DATE:	**02/17/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Companies, Inc. **300 Welcome Center Blvd.** **Welcome, NC 27374**	**Series "8100/1100/3100/10/1000/200"** **Mulled Triple Vinyl Single Hung Window** **w/Finless Installation** Configuration: O/XO/XO/X Glazing: Insulating Glass (Annealed) Frame: W-2769mm(109") H-1880mm(74") Sash: W-832mm(32.75") H-911mm(35.88")

SPECIFICATION	PRODUCT RATING
AAMA 450-10 **AAMA/WDMA/CSA 101/I.S.2/A440-17** **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08**	**Applied Rating: LC50** **Mulled Fenestration Rating: LC50** **Class LC-PG50 2769 x 1880 (109 x 74)-H** **Design Pressure: ±2400 Pa (50 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)**

Product Tested By: Architectural Testing, Inc.
Report No: D9518.01-801-47/D9519.01-801-47(Gateway)/W-2009
Expiration Date: **July 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com