

Hallmark® Certificate of Conformance and License (CCL)



Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413

For more Information visit www.amscert.com

Website: www.kolbewindows.com

TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
413-H-1298.00	Ultra Inswing Fiberglass French Door Combination Mulled Alongside an Ultra Inswing Fiberglass Fixed Door with an Ultra Transom (URDHSS) Combination Mulled Above (SP) (R&D #14065)	101/I.S.2/A440-11	Class R-PG35; Size Tested 1883 x 2480 Type-LW SHD; DP +35/-35 psf; Can. Air Infil/Exfil. Level=A2	1883mm	2480mm	ESP018123P-1636	4/3/2015	3/4/2025
413-H-1298.01	Ultra Inswing Fiberglass French Door Combination Mulled Alongside an Ultra Inswing Fiberglass Fixed Door with an Ultra Transom (URDHSS) Combination Mulled Above (SP) (R&D #14065)	101/I.S.2/A440-11	Class LC-PG25; Size Tested 953 x 2480 Type-FD; DP +35/-35 psf; Water Test Press 180Pa (3.76psf); Can. Air Infil/Exfil. Level=A3	953mm	2480mm	ESP018123P-1636	4/3/2015	3/4/2025
413-H-1298.02	Ultra Inswing Fiberglass French Door Combination Mulled Alongside an Ultra Inswing Fiberglass Fixed Door with an Ultra Transom (URDHSS) Combination Mulled Above (SP) (R&D #14065)	101/I.S.2/A440-11	Class LC-PG35; Size Tested 2835 x 600 Type-TR; DP +35/-35 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	2835mm	600mm	ESP018123P-1636	4/3/2015	3/4/2025
413-H-1298.03	Ultra Inswing Fiberglass French Door Combination Mulled Alongside an Ultra Inswing Fiberglass Fixed Door with an Ultra Transom (URDHSS) Combination Mulled Above (SP) (R&D #14065)	101/I.S.2/A440-11	Class R-PG35 – Size tested 2835mm Span/1540mm Tributary Width (111.63 in. span/60.63 in. tributary width) – MA (Combination Horizontal Mull); DP +35/-35 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	1540mm trib width	2835mm span	ESP018123P-1636	4/3/2015	3/4/2025
413-H-1298.04	Ultra Inswing Fiberglass French Door Combination Mulled Alongside an Ultra Inswing Fiberglass Fixed Door with an Ultra Transom (URDHSS) Combination Mulled Above (SP) (R&D #14065)	101/I.S.2/A440-11	Class R-PG35 – Size tested 2480mm Span/953mm Tributary Width (97.63 in. span/37.5 in. tributary width) – MA (Combination Vertical Mull); DP +35/-35 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	953mm trib width	2480mm span	ESP018123P-1636	4/3/2015	3/4/2025
413-H-1298.07	Ultra Inswing Fiberglass French Door Combination Mulled Alongside an Ultra Inswing Fiberglass Fixed Door with an Ultra Transom (URDHSS) Combination Mulled Above (SP) (R&D #14065)	AAMA 450-10	Class R-PG35 – Size tested 2835mm Span/1540mm Tributary Width (111.63 in. span/60.63 in. tributary width) – MA (Combination Horizontal Mull); DP +35/-35 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	1540mm	2835mm	ESP018123P-1636	4/3/2015	3/4/2025

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413


For more Information visit www.amscert.com

Website: www.kolbewindows.com

TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
413-H-1298.08	Ultra Inswing Fiberglass French Door Combination Mulled Alongside an Ultra Inswing Fiberglass Fixed Door with an Ultra Transom (URDHSS) Combination Mulled Above (SP) (R&D #14065)	AAMA 450-10	Class R-PG35 – Size tested 2480mm Span/953mm Tributary Width (97.63 in. span/37.5 in. tributary width) – MA (Combination Vertical Mull); DP +35/-35 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	953mm	2480mm	ESP018123P-1636	4/3/2015	3/4/2025

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com