NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI012941.03-R3**
DATE:	**11/30/2015**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Atrium**
CODE:	**1373-1**
REVISION DATE:	**06/02/2025**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Companies, Inc. **9001 Ambassador Row** **Dallas, TX 75247**	**Series "8900/90/8000/1800/3900"** **Vinyl Fixed Window** **w/Fin Installation** Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1829mm(72") H-1829mm(72") DLO: W-1694mm(66.63") H-1694mm(66.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08** **AAMA/WDMA/CSA 101/I.S.2/A440-05**	**Class CW-PG50 1829 x 1829 (72 x 72)-FW** **FW-C50 1829 x 1829 (72 x 72)** **Design Pressure: ±2400 Pa (50 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)**

Product Tested By: Architectural Testing, Inc.
Report No: D5176.01-801-47/D2321.01-801-47/W-1996
Expiration Date: **November 30, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com