

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012941.04-R3
DATE: 11/30/2015
CERTIFICATION PROGRAM: Structural
COMPANY: Atrium
CODE: 1373-1
REVISION DATE: 06/02/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Companies, Inc. 9001 Ambassador Row Dallas, TX 75247	Series "8900/90/8000/1800/3900" Triple Vinyl Fixed Window w/Fin & Finless Installation Configuration: OOO Glazing: Insulating Glass (Tempered) Frame: W-3378mm(133") H-1829mm(72") Individual: W-1118mm(44") H-1829mm(72") Mullion: W-29mm(1.13") H-1829mm(72")

SPECIFICATION	PRODUCT RATING
AAMA 450-10 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Applied Rating: R50 Mulled Fenestration Rating: R50 Class CW-PG50 1829 x 1829 (72 x 72)-FW FW-R50 1829 x 1829 (72 x 72) Design Pressure: ±2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Architectural Testing, Inc.
Report No: D6247.01-801-44/D2321.01-801-47/W-1996
Expiration Date: November 30, 2029

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023