

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013109-R4
DATE: 04/11/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Atrium
CODE: 1373-1
REVISION DATE: 09/05/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Companies, Inc. 300 Welcome Center Blvd. Welcome, NC 27374	Series "120/130" Vinyl Fixed Window w/Fin Installation Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1829mm(72") H-1829mm(72") DLO: W-1708mm(67.25") H-1708mm(67.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class LC-PG50 1829 x 1829 (72 x 72)-FW FW-LC50 1829 x 1829 (72 x 72) Design Pressure: ±2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Architectural Testing, Inc.
Report No: D5173.01-801-47/W-2009
Expiration Date: February 28, 2029

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com

NOPC-03/30/2023