NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013301.05-R4**
DATE:	**07/20/2016**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Atrium**
CODE:	**2187-1**
REVISION DATE:	**02/17/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Companies, Inc. **300 Welcome Center Blvd.** **Welcome, NC 27374**	**Series "120/130"** **Vinyl Fixed Window** **w/Fin Installation** Configuration: OOO Glazing: Insulating Glass (Annealed) Frame: W-2743mm(108") H-2134mm(84") DLO: W-783mm(30.81") H-2011mm(79.19")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08** **AAMA/WDMA/CSA 101/I.S.2/A440-05**	**Class LC-PG40 2743 x 2134 (108 x 84)-FW** **FW-LC40 2743 x 2134 (108 x 84)** **Design Pressure: ±1920 Pa (40 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)**

Product Tested By: Architectural Testing, Inc.
Report No: C9847.01-801-47/W-2009
Expiration Date: **July 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com