# NOTICE OF PRODUCT CERTIFICATION

| | |
|---|---|
| **CERTIFICATION NO:** | **NI013304-R4** |
| **DATE:** | **07/20/2016** |
| **CERTIFICATION PROGRAM:** | **Structural** |
| **COMPANY:** | **Atrium** |
| **CODE:** | **2187-1** |
| **REVISION DATE:** | **02/18/2026** |

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| **Atrium Companies, Inc.**<br>**300 Welcome Center Blvd.**<br>**Welcome, NC 27374** | **Series "336"**<br>**Vinyl Side Lite Window**<br>**w/Fin Installation**<br>Configuration: O<br>Glazing: Insulating Glass (Annealed)<br>Frame: W-705mm(27.75") H-2026mm(79.75")<br>DLO: W-606mm(23.88") H-1829mm(72") |

| SPECIFICATION | PRODUCT RATING |
|---|---|
| **AAMA/WDMA/CSA 101/I.S.2/A440-17**<br>**AAMA/WDMA/CSA 101/I.S.2/A440-11**<br>**AAMA/WDMA/CSA 101/I.S.2/A440-08**<br>**AAMA/WDMA/CSA 101/I.S.2/A440-05** | **Class R-PG50 711 x 2032 (28 x 80)-SLT**<br>**SLT-R50 711 x 2032 (28 x 80)**<br>**Design Pressure: ±2400 Pa (50 psf)**<br>**Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)** |

Product Tested By: Architectural Testing, Inc.
Report No: C8740.01-801-47/W-2009
Expiration Date: **July 31, 2030**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.**
**4794 George Washington Memorial Highway**
**Hayes, VA 23072**
**Tel: (804) 684-5124**
**Email: nami@namiinc.com**