

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012955.01-R4
DATE: 12/07/2015
CERTIFICATION PROGRAM: Structural
COMPANY: Atrium
CODE: 1373-1
REVISION DATE: 06/02/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Companies, Inc. 9001 Ambassador Row Dallas, TX 75247	Series "8900/90/8000/1800/3900" Vinyl Horizontal Sliding Window w/Finless Installation Configuration: XX Glazing: Insulating Glass (Annealed) Frame: W-1829mm(72") H-1219mm(48") Sash: W-881mm(34.69") H-1118mm(44") DLO: W-806mm(31.75") H-1041mm(41")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class R-PG50 1829 x 1219 (72 x 48)-HS HS-R50 1829 x 1219 (72 x 48) Design Pressure: ±2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf)

Product Tested By: Architectural Testing, Inc.
Report No: B8807.01-801-47/W-1840/W-1996
Expiration Date: December 31, 2029

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023