

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013079-R4
DATE: 03/29/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Atrium
CODE: 2187-1
REVISION DATE: 09/04/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Companies, Inc. 300 Welcome Center Blvd. Welcome, NC 27374	Series "451/461" Vinyl Horizontal Sliding Window w/Fin Installation Configuration: XOX Glazing: Insulating Glass (Annealed) Frame: W-2438mm(96") H-1219mm(48") Vent: W-808mm(31.81") H-1116mm(43.94") DLO: W-730mm(28.75") H-1080mm(42.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class R-PG25 2438 x 1219 (96 x 48)-HS HS-R25 2438 x 1219 (96 x 48) Design Pressure: ±1200 Pa (25 psf) Water Penetration Resistance Test Pressure: 180 Pa (3.76 psf)

Product Tested By: Architectural Testing, Inc.
Report No: D4153.01-801-47/W-2009
Expiration Date: March 31, 2029

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com

NOPC-03/30/2023