

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013080-R4
DATE: 03/29/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Atrium
CODE: 2187-1
REVISION DATE: 09/05/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Companies, Inc. 300 Welcome Center Blvd. Welcome, NC 27374	Series "8100/1100/3100/10/1000/200" Vinyl Horizontal Sliding Window w/Finless Installation Configuration: XOX Glazing: Insulating Glass (Annealed) Frame: W-2743mm(108") H-1219mm(48") Vent: W-902mm(35.5") H-1140mm(44.88") DLO: W-835mm(32.88") H-1081mm(42.56")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class R-PG30 2743x 1219 (108 x 48)-HS HS-R30 2743x 1219 (108 x 48) Design Pressure: ±1440 Pa (30 psf) Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf)

Product Tested By: Architectural Testing, Inc.
Report No: D9514.01-801-47/W-2009
Expiration Date: March 31, 2029

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com

NOPC-03/30/2023