NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013080.01-R4**
DATE:	**03/29/2016**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Atrium**
CODE:	**2187-1**
REVISION DATE:	**09/05/2024**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Companies, Inc. **300 Welcome Center Blvd.** **Welcome, NC 27374**	**Series "8100/1100/3100/10/1000/200"** **Vinyl Horizontal Sliding Window** **w/Finless Installation** Configuration: XO Glazing: Insulating Glass (Annealed) Frame: W-1829mm(72") H-1219mm(48") Vent: W-886mm(34.88") H-1143mm(45") DLO: W-833mm(32.81") H-1076mm(42.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 **AAMA/WDMA/CSA 101/I.S.2/A440-17** **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08**	**Class R-PG30 1829x 1219 (72 x 48)-HS** **HS-R30 1829x 1219 (72 x 48)** **Design Pressure: ±1440 Pa (30 psf)** **Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf)**

Product Tested By: Architectural Testing, Inc.
Report No: D9514.01-801-47/W-2009
Expiration Date: **March 31, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com