

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012949.04-R4
DATE: 12/04/2015
CERTIFICATION PROGRAM: Structural
COMPANY: Atrium
CODE: 1373-1
REVISION DATE: 03/03/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Companies, Inc. 9001 Ambassador Row Dallas, TX 75247	Series "8900/90/8000/1800/3900" Triple Vinyl Double Hung Window w/Finless Installation Configuration: X/X//X/X//X/X Glazing: Insulating Glass (Annealed) Frame: W-2769mm(109") H-1880mm(74") Individual: W-914mm(36") H-1880mm(74") DLO: W-724mm(28.5") H-829mm(32.63")

SPECIFICATION	PRODUCT RATING
AAMA 450-10 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Applied Rating: LC50 Mulled Fenestration Rating: LC50 Class LC-PG50 914 x 1880* (36 x 74*)-H H-LC50 914 x 1880* (36 x 74*) Design Pressure: ±2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf)

Product Tested By: Architectural Testing, Inc.
Report No: B8803.01-801-47/ B8802.01-801-47/W-1839/W-1996
Expiration Date: **December 31, 2029**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi" or similar, written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023