

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012953.01-R7
DATE: 12/07/2015
CERTIFICATION PROGRAM: Structural
COMPANY: Atrium
CODE: 1373-1
REVISION DATE: 03/03/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Companies, Inc. 9001 Ambassador Row Dallas, TX 75247	Series "8900/90/8000/1800/3900" Vinyl Double Hung Window w/Fin Installation Configuration: X/X Glazing: Insulating Glass (Annealed) Frame: W-1118mm(44") H-1873mm(73.75") Sash: W-1022mm(40.25") H-927mm(36.5") DLO: W-926mm(36.44") H-826mm(32.5")

SPECIFICATION	PRODUCT RATING
ASTM E330-02/14	Design Pressure: ±2160 Pa (45 psf)

Product Tested By: Architectural Testing, Inc.
Report No: C1750.01-801-47/W-1839/W-2074
Expiration Date: December 31, 2029

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023