NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013073.08-R4**
DATE:	**03/28/2016**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Atrium**
CODE:	**2187-1**
REVISION DATE:	**09/05/2024**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Companies, Inc. **300 Welcome Center Blvd.** **Welcome, NC 27374**	**Series "450/455/460/465" Mulled** **Triple Vinyl Double Hung Window** **w/o Mull Clips & w/Fin Installation** Configuration: X/XX/XX/X Glazing: Insulating Glass (Annealed) Frame: W-2769mm(109") H-1880mm(74") Sash: W-835mm(32.88") H-927mm(36.5") DLO: W-745mm(29.31") H-838mm(33")

SPECIFICATION	PRODUCT RATING
AAMA 450-10/20 **AAMA/WDMA/CSA 101/I.S.2/A440-22** **AAMA/WDMA/CSA 101/I.S.2/A440-17** **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08** **AAMA/WDMA/CSA 101/I.S.2/A440-05**	**Applied Rating: LC35** **Mulled Fenestration Rating: LC35** **Class LC-PG35 2769 x 1880 (109 x 74)-H** **Design Pressure: ±1680 Pa (35 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)**

Product Tested By: Architectural Testing, Inc.
Report No: C1745.01-801-47/97399.01-801-47/97395.01-801-47 (Gateway)/W-2009
Expiration Date: **March 31, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com