

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013077-R6
DATE: 03/28/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Atrium
CODE: 2187-1
REVISION DATE: 09/05/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Companies, Inc. 300 Welcome Center Blvd. Welcome, NC 27374	Series "8300/3000/3201/40/1300" Vinyl Double Hung Window w/Finless Installation Configuration: X/X Glazing: Insulating Glass (Annealed) Frame: W-1219mm(48") H-1981mm(78") Sash: W-1133mm(44.63") H-976mm(38.44") DLO: W-1067mm(42") H-906mm(35.69")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class LC-PG25 1219 x 1981 (48 x 78)-H H-LC25 1219 x 1981 (48 x 78) Design Pressure: ±1200 Pa (25 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)

Product Tested By: Architectural Testing, Inc.
Report No: C7602.01-801-47/W-1923/W-1995/W-2009
Expiration Date: March 31, 2029

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com

NOPC-03/30/2023