

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013077.02-R5
DATE: 03/28/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Atrium
CODE: 2187-1
REVISION DATE: 03/03/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Companies, Inc. 300 Welcome Center Blvd. Welcome, NC 27374	Series "8300/3000/3201/40/1300" Muller Twin Vinyl Double Hung Window w/Transom & Finless Installation Configuration: O/X/XX/X Glazing: Insulating Glass (Annealed) Frame: W-1829mm(72") H-2743mm(108") Sash: W-829mm(32.63") H-897mm(35.31") Transom: W-1829mm(72") H-902mm(36")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Applied Rating: LC35 Muller Fenestration Rating: LC35 Class LC-PG35 1829 x 2743 (72 x 108)-H H-LC35 1829 x 2743 (72 x 108) Design Pressure: ±1680 Pa (35 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)

Product Tested By: Architectural Testing, Inc.
Report No: D9515.01-801-47/C7602.01-801-47/B6835.01-801-47/W-1995/W-1996
Expiration Date: March 31, 2029

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023