

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013290.03  
**DATE:** 08/03/2016  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Continental Glass  
**CODE:** 2103-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS  | PRODUCT DESCRIPTION   |
|---|---|
| <b>Continental Glass Systems, LLC</b><br><b>325 West 74 Place</b><br><b>Hialeah, FL 33014</b> | <b>Series "10000" Glazed Aluminum</b><br><b>Out-Swing Side-Hinged Door</b><br><b>w/Transom, ADA Sill &amp;</b><br><b>Regent or DNW Multipoint Hardware</b><br><br>Configuration: O/XX<br>Glazing: Laminate-1/4" Heat Strengthened Glass/0.090" Kuraray SentryGlas Plus Interlayer/1/4" Heat Strengthened Glass or Laminate-1/4" Heat Strengthened Glass/0.075" Eastman Saflex CP Interlayer/1/4" Heat Strengthened Glass<br><br>Frame: W-2184mm(86") H-3656mm(144")<br>DLO: W-778mm(30.63") H-2661mm(104.75") |

| SPECIFICATION             | PRODUCT RATING  |
|---------------------------|---|
| <b>TAS 201/202/203-94</b> | <b>Design Pressure: 4309 Pa (90 psf)</b><br><b>Large Missile Impact Rated</b> |

Product Tested By: Blackwater Testing, Inc  
Report No: BT-CON-16-001/FTL 5567/FTL 6132/W-1782  
Expiration Date: July 31, 2020

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'S. D.', is written over the signature line.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122