

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013290.09  
**DATE:** 08/03/2016  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Continental Glass  
**CODE:** 2103-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Continental Glass Systems, LLC</b> <b>325 West 74 Place</b> <b>Hialeah, FL 33014</b>	<b>Series "10000" Glazed Aluminum</b> <b>In-Swing Side-Hinged Door</b> <b>w/Transom, ADA Sill &amp;</b> <b>Regent or DNW Multipoint Hardware</b>  Configuration: O/XX Glazing: Laminate-1/4" Heat Strengthened Glass/0.090" Kuraray SentryGlas Plus Interlayer/1/4" Heat Strengthened Glass or Laminate-1/4" Heat Strengthened Glass/0.075" Eastman Saflex CP Interlayer/1/4" Heat Strengthened Glass  Frame: W-2184mm(86") H-3658mm(144")  DLO: W-778mm(30.63") H-2661mm(104.75")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: 4309 Pa (90 psf)</b> <b>Large Missile Impact Rated</b>

Product Tested By: Blackwater Testing, Inc  
Report No: BT-CON-16-001/FTL 5567/FTL 6132/W-1782  
Expiration Date: **July 31, 2020**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122