

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011154-R4
DATE: 06/19/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Moss Supply
CODE: 206-1
REVISION DATE: 04/27/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Moss Supply Company 5001 North Graham Street Charlotte, NC 28269	Series "3400 New Construction PW" Vinyl Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1422mm(56") H-1600mm(63") DLO: W-1308mm(51.5") H-1486mm(58.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG50 1422 x 1600 (56 x 63)-FW Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf)

Product Tested By: Quast Consulting & Testing, Inc.
Report No: QCT12-2521.02
Expiration Date: April 30, 2032

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com