



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program



AUTHORIZATION FOR PRODUCT CERTIFICATION

MI Windows & Doors, LLC
P.O. Box 370
Gratz, PA 17030-0370

Attn: Rick Sawdey

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION	RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S. 2/A440-11 R-PG35*-914x1880 (36x74)-H Negative Design Pressure = -50 psf				
COMPANY AND CODE	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
MI Windows & Doors, LLC Code: MTL	16418	1650 DH (FIN & FINLESS) (PVC)(X/X)(OG)(INS GL) (MODIF)(REINF)(TILT) (ASTM)	FRAME 914 mm x 1880 mm (3'0" x 6'2")	SASH 826 mm x 921 mm (2'9" x 3'0")
Design Pressure (psf): +50/-50 (Pa): +2400/-2400		Water Test Pressure (psf): 5.43 (Pa): 260		


This Certification will expire **December 7, 2026 (extended from December 7, 2021 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Product Tested and Reported by: **Architectural Testing, Inc.**

Report No.: **G2924.01-109-47**

Date of Report: **March 24, 2017 (Revised July 19, 2019)**

Evaluated for Certification: **August 17, 2021**


Associated Laboratories, Inc.

Authorized for Certification: **August 17, 2021**


Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)