



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program



AUTHORIZATION FOR PRODUCT CERTIFICATION

MI Windows & Doors, LLC
P.O. Box 370
Gratz, PA 17030-0370

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION	RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-17 R-PG40*-914x1524 (36x60)-H Negative Design Pressure = -55 psf				
COMPANY AND CODE	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
MI Windows & Doors, LLC Code: MTL	21676	1650 DH (FINLESS) (PVC)(X/X)(OG)(INS GL) (MODIF)(REINF)(TILT) (ASTM)	<u>FRAME</u> 914 mm x 1524 mm (36" x 60")	<u>SASH</u> 829 mm x 746 mm (33" x 29")
Design Pressure (psf): +50/-55 (Pa): +2400/-2640		Water Test Pressure (psf): 6.06 (Pa): 290		

This Certification will expire **January 31, 2029** and requires validation until then by continued listing in the current AAMA Certified Products Directory.


Product Tested and Reported by: **Molimo, LLC**

Report No.: **28138.05-106-12**

Date of Report: **March 6, 2024**

Date Test Completed: **January 31, 2024**

Evaluated for Certification: **March 7, 2024**


Associated Laboratories, Inc.

Authorized for Certification: **March 7, 2024**


Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)